



防爆合格证

证号: GYB091448

由 广州市章和电气设备有限公司
(地址: 广州高新技术产业开发区科学城科学大道 111 号 701-4、702-4)

制造的产品:

名称 液位浮子传感器

型号规格 L30

防爆标志 Ex ia II CT6

产品标准 液位浮子传感器制造工艺及考核标准

图样编号 20031008 - 1~10

经图样及技术文件的审查和样品检验, 确认上述产品
符合 GB3836.1 - 2000、GB3836.4 - 2000 标准,
特颁发此证。有效期自颁发日期起伍 年内有效。

备注

1. 产品使用注意事项见使用说明书。
2. 产品的本安参数: $U_i = 28V$; $I_i = 119mA$; $P_i = 0.84W$; $C_i \approx 0\mu F$; $L_i \approx 0mH$

站长

国家级仪器仪表防爆安全监督检验站

颁发日期

二〇〇九年 六 月二十三日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: 0086 21 64368180
传真: 0086 21 64844580



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert No.

This is to certify that the product

manufactured by

which model is

Ex marking

product standard

drawing number

has been inspected and certified by NEPSI, and that it conforms to

This Approval shall remain in force until

Remarks

Director

**National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation**

Issued Date

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

**103 Cao Bao Road
Shanghai 200233, China**

**<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn**

**Tel:0086 21 64368180
Fax:0086 21 64844580**